



PRODUCTS:

1. BIG F PRO 156
2. BIG F PRO 256
2. BIG F PRO 267

**PERFORMANCE
DATA SHEET**



PERFORMANCE DATA SHEET

MANUFACTURER

Name: ATLAS FILTRI SRL
Address: Via Pierobon 32 - Limena, 35010, PD
Phone: +39 049769055

SELLER

Name: Atlas FILTRI SRL distributors

PRODUCTS

- *BIG F PRO 156*
- *BIG F PRO 256*
- *BIG F PRO 267*



SUBSTANCES REDUCTION

The **Atlas Filtri** models listed above have been tested and certified under **AS/NZS 4020 and AS/NZS 3497 and relevant NSF Standard listed in Clause 1.2 for reduction of Sediment**. The performance of these products has been verified and substantiated as the test data summarized below indicates. These substances may not be in your water.

CLASS	TREATMENT TYPE	PLAIN LANGUAGE DESCRIPTION	CONFORMANCE TO NSF STANDARDS AND PROTOCOLS
IV	Turbidity and particulate removal	Reduce Cloudiness	NSF 42

SUBSTANCE	NHMRC ADWG or USEPA SDWA MCL	AVERAG INFLUENT CONCENTRATION	MAXIMUM EFFLUENT CONCENTRATION	MINIMUM PERCENT REMOVAL	AVERAGE EFFLUENT CONCENTRATION	AVERAGE PERCENT REMOVAL
Sediments	-	12913	293	> 97.76%	84	> 99.36%

MCL - Maximum Contaminant level
Mg/l - milligrams per litre

Testing conditions:

- Flow rate was controlled at 24 gpm
- pH 7,8 +/- 0,05
- Temperature 21 +/- 3 degree C

Refer to your owner's guide for more specific product and warranty information and to avoid contamination from improper handling and installation. Performance will vary on local water conditions. The substances reduced by this product are not necessarily in your water.

USE GUIDELINE

- Minimum Operating pressure 50 kPa
- Maximum operating pressure 1205 kPa
- Do not Allow exposure to temperature below 4°C
- Maximum operating temperature 45°C
- Nominal Flow rate

MODEL	FLOW-RATE
DP BIG 156	54 L/min
DP BIG 256	70 L/min
DP BIG 267	95 L/min

- This system has to installed according to local plumbing codes on the cold water line
- Replacement cartridges

MODEL	CARTRIDGE
DP BIG 156	TS 10 BIG - CPP 10 BIG
DP BIG 256	TS 20 BIG - CPP 20 BIG
DP BIG 267	TS 20 BIG - CPP 20 BIG

- This system requires regular replacement of the filter cartridge to maintain proper operation. Varying Sediment or organic substances levels may affect replacement frequency.
- Be sure to change the filter cartridge at least every six months; Or whenever you detect a change in taste or odour or decrease in flow.



CAUTION - Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. This System may be used on disinfected water that may contain filterable cyst.

Date: 31/03/2026

Manufacturer's Signature



IT'S MADE IN ITALY



www.atlasfiltri.com